

Page 1 of 2 Reference No: 100204D-ELSA

Statement of conformity

Product: Solar inverter

Tested on request of: ABB Oy Drives, P.O. Box 184, FI-00381 Helsinki, FINLAND

Name and address of the manufacturer: ABB Oy Drives, P.O. Box 184, FI-00381 Helsinki, FINLAND

Rating and principal characteristics: See page 2.

Trade mark: ABB

Model/Type reference: PVS300-TL-xxxxW-2, See page 2 for details.

Additional information Part of testing according to TMP procedure at ABB Oy Drives,

Hiomotie 13, FI-00380 Helsinki, FINLAND. See test report for

details.

The product has been tested and found to be in conformity with

the current standard EN 50178:1997 and IEC 62103:2003 (1st Ed) as shown

in the test report reference no. 100204C-ELSA.

This Statement is only valid for the tested sample.

Hyvinkää 5.4.2011

Eino Julmala

Senior Testing Engineer

Com Julmala



This information is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this information. Any observations and results in this report are relevant only to the sample tested. Only the Client is authorised to copy and distribute this information and only then in its entirety and accompanied by the associated full report.

Intertek ETL Semko Oy Koneenkatu 12 (Door K1) FI-05830 Hyvinkää Finland Business ID: 1871439-4 Phone +358 10 424 6200 Telefax +358 10 424 6201







Page 2 of 2 Reference No: 100204D-ELSA

Ratings and principal characteristics and Model/Type reference:

| Model | V _{DC,max} | $V_{MPP,min}$ | $V_{MPP,max}$ | P _{PV,max} | I _{DC,max} | $V_{AC,r}$ | f_r | Cos φ | P _{AC,r} | I _{AC,max} |
|-------------------|---------------------|---------------|---------------|---------------------|---------------------|------------|-------|-------|-------------------|---------------------|
| PVS300-TL-3300W-2 | 900 V | 335 V | 800 V | 3700 W | 10,5 A | 230 V | 50 Hz | 1 | 3300 W | 15,6 A |
| PVS300-TL-4000W-2 | 900 V | 335 V | 800 V | 4500 W | 12,7 A | 230 V | 50 Hz | 1 | 4000 W | 18,9 A |
| PVS300-TL-4600W-2 | 900 V | 335 V | 800 V | 5200 W | 14,6 A | 230 V | 50 Hz | 1 | 4600 W | 21,7 A |
| PVS300-TL-6000W-2 | 900 V | 335 V | 800 V | 6700 W | 19,0 A | 230 V | 50 Hz | 1 | 6000 W | 28,3 A |
| PVS300-TL-8000W-2 | 900 V | 335 V | 800 V | 8900 W | 25,4 A | 230 V | 50 Hz | 1 | 8000 W | 37,7 A |

This information is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this information. Any observations and results in this report are relevant only to the sample tested. Only the Client is authorised to copy and distribute this information and only then in its entirety and accompanied by the associated full report.

Intertek ETL Semko Oy Koneenkatu 12 (Door K1) FI-05830 Hyvinkää Finland Business ID: 1871439-4 Phone +358 10 424 6200 Telefax +358 10 424 6201



