



Test Certificate

N° 2210 / 1230-VDE-E3 - CER

SGS Tecnos, S.A., Electrical Testing Laboratory accredited, according for testing of "SAFETY OF ELECTRICAL / ELECTRONICS, ME & IT EQUIPMENTS" and "ELECTROMAGNETIC COMPATIBILITY".

CERTIFIES that the next products:

Equipment Description.....:	SOLAR INVERTERS
Trade Mark	ABB Oy
Models	PVS800-57-0100kW-A(1); PVS800-57-0250kW-A(2), PVS800-57-0500kW-A(2); PVS800-57-0630kW-B(3); PVS800-57-0315kW-B(3), PVS800-57-0750kW-A(3); PVS800-57-0875kW-B(3) and PVS800-57-1000kW-C(3).
(1):Model fully tested (2):Models partially tested (3):Extension models	
Control version	ISXR7330
Ratings.....:	<p>MODEL: PVS800-57-0100kW-A Input: 450-825 Vdc (1000 Vdc MAX.) 230 A MAX. Output: 300 V 3 ~ 50/60 Hz 100 kW 195 A</p> <p>MODEL: PVS800-57-0500kW-A Input: 450-825 Vdc (1000 Vdc MAX.) 1145 A MAX. Output: 300 V 3 ~ 50/60 Hz 500 kW 965 A</p> <p>MODEL: PVS800-57-0630kW-B Input: 525-825 Vdc (1000 Vdc MAX.) 1230 A MAX. Output: 350 V 3 ~ 50/60 Hz 500 kW 1040 A</p> <p>MODEL: PVS800-57-0250kW-A Input: 450-825 Vdc (1000 Vdc MAX.) 575 A MAX. Output: 300 V 3 ~ 50/60 Hz 250 kW 485 A</p> <p>MODEL: PVS800-57-0315kW-B Input: 525-825 Vdc (1000 Vdc MAX.) 615A MAX. Output: 350 V 3 ~ 50/60 Hz 250 kW 520 A</p> <p>MODEL: PVS800-57-0750kW-A Input: 450-825 Vdc (1100 Vdc MAX.) 1710 A MAX. Output: 300 V 3 ~ 50/60 Hz 750 kW 1445 A</p> <p>MODEL: PVS800-57-0875kW-B Input: 525-825 Vdc (1100 Vdc MAX.) 1710 A MAX. Output: 350 V 3 ~ 50/60 Hz 875 kW 1445 A</p> <p>MODEL: PVS800-57-1000kW-C Input: 600-850 Vdc (1100 Vdc MAX.) 1710 A MAX. Output: 400 V 3 ~ 50/60 Hz 1000 kW 1445 A</p>
Applicant & Manufacturer	ABB Oy Drives
Address	Hiomotie, 13. - P.O. Box 184. 00381 HELSINKI (Finland)

Were tested and found to be in **CONFORMITY** with the applicable requirements specified in the next standard:

- **VDE 0126-1-1:2006**, Automatic disconnection device between a generator and the public low-voltage grid.

This certificate, issued by SGS Tecnos, is laid down upon results, analysis y verifications detailed in the reference Test Report n° 2210/1230-VDE-E2.

Madrid, March, 22th 2013



FERNANDO MONTES CLAVER
Technical Manager of the E&E Lab

This Certificate applies only to the checking of Test Report and the verifying of correct application of harmonised standards.
This Certificate does not indicate any measure of Approval, Certification, Supervision, Control or Surveillance by SGS to this or any related product.
This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.