

Certificate No:12110201/00



**ASA**

Australian Safety Approval

**CERTIFICATE OF SUITABILITY**

**Power-One Energy Solutions Pty Ltd**  
**3/4 Avenue of Americas**  
**Newington, NSW, 2127**  
**Australia**

|                          |   |
|--------------------------|---|
| <b>Class</b>             | <b>Non Declared</b>   |
| <b>Product:</b>          | <b>Micro Inverter</b>   |
| <b>Brand Name:</b>       | <b>Aurora Micro</b>   |
| <b>Model Number:</b>     | <b>MICRO-0.3-I-OUTD-230 and<br/>MICRO-0.25-I-OUTD-230 Similar to MICRO-0.3-I-OUTD-230<br/>except rated output of 1.3A, 250W in lieu of 1.5A, 300W</b> |
| <b>Ratings:</b>          | <b>Input: 12-60Vdc, 10.5A and , IP65<br/>Output: 230Vac, 50Hz, 1.5A, 300W and 1.3A, 250W</b>  |
| <b>Standard:</b>         | <b>AS 4777.3-2005<br/>AS 4777.2-2005<br/>AS/NZS 3100:2009 + A1<br/>AS/NZS60950.1:2011</b>   |
| <b>Approval Mark:</b>    | <b>ASA12110201</b>  |
| <b>Date of Approval:</b> | <b>22 November 2012</b>   |
| <b>Date of Expiry:</b>   | <b>21 November 2017</b>   |

For and on Behalf of Australian Safety Approval



ASA Electrical Product Safety Certification Scheme confirms, in accordance with ISO/IEC Guide 65, that the electrical product described above complied with the minimum safety standards listed. This Certificate does not confirm that the described equipment complies with claims of Performance.

**JAS-ANZ**



[www.jas-anz.org/register](http://www.jas-anz.org/register)