

ATTESTATION OF CONFORMITY

ATTESTATO DI CONFORMITA'

Attestation number

Attestato numero : 3502387.05

Issued to

Rilasciato a : Power-One Italy S.p.a.
Via S. Giorgio 642
I-52028 Terranuova Bracciolini (AR)
Italy

Manufacturer

Costruttore : Power-One Italy S.p.a.
Via S. Giorgio 642
I-52028 Terranuova Bracciolini (AR)
Italy

Product Type

Tipo prodotto : Photovoltaic grid tied inverter

Model reference

Riferimento Modello : MICRO-0.3-I-OUTD-230;
MICRO-0.25-I-OUTD-230; MICRO-0.25-I-OUTD-230-ACPV

Firmware release

Revisione firmware : DSP: B1.58 Checksum 0X468E

Testing Laboratory

Laboratorio prove : DEKRA at Power-One Italy S.p.a. ,Via S. Giorgio 642,
I-52028 Terranuova Bracciolini (AR), Italy

Test report No.

Rapporto Nr. : 3502387.55

Requirements

Requisiti : IEC 62116:2008 ; EN 62116:2011

Remarks

This Attestation of Conformity replaces the DEKRA AoC having same number and dated 16 October 2012.
Questo Attestato di Conformita' sostituisce l' attestato DEKRA avente stesso numero e datato 16 Ottobre 2012

This Attestation covers the following alternative changes in construction:

Questo Attestato copre le seguenti alternative nella costruzione:

- Optional use of Extended assembly wiring, by Amphenol LTW, model SPS-03AMFM-LL7CXX, where XX is a two digit figure denoting assembly length (3 to 5 meters), C denotes the type of cable and maybe D for HAR type cable or E for 2Pfg 1940 type cable (XLPO jacket). Rated 300 Vac, 5 A, -40 to +90 °C.
To be connected to the AC Output cable (AC Output wiring harness). One side of the mentioned extended assembly cable terminates with receptacle (Plug) 3 positions with female pins the other side terminates with free wiring. Local Electrical codes should be taken into consideration during installation of the equipment incorporating the extended assembly wiring.
- Use of alternative DC connector (+) Multicontact MC4 Series (model PV-ADSP4-S2-UR/6) rated 1000 Vdc, 30 A.
- Use of alternative DC connector (-) Multicontact MC4 Series (model PV-ADBP4-S2-UR/6) rated 1000 Vdc, 30 A.
- Use of the following alternative PWB: ZGN.V0J06.0 or ZGN.V0J06.1.
- Use of alternative electrical rating for operating frequency 50/60 Hz.
- Use of alternative Trade-Mark ABB.
- Editorial correction of operating temperature range.

3502387.05

The undersigned declares that the above described product meets the above mentioned technical specification. This attestation of conformity is issued based on the test results as laid down in the referred Test Report . The investigation does not include an assessment of the manufacturer's production.

Il sottoscritto dichiara che il prodotto di cui sopra è conforme ai requisiti tecnici menzionati. Questo attestato di conformità è rilasciato sulla base dei risultati di prova riferiti nel rapporto sopra menzionato.

La valutazione non include una verifica del luogo di produzione.

If a DEKRA Authorization to apply the DEKRA VERIFIED INVERTER mark has been issued by DEKRA on the subject product, this attestation of conformity authorizes the manufacturer to make reference to the "Requirements" object of this attestation, inside the DEKRA VERIFIED INVERTER seal .

Se il prodotto in oggetto è licenziatario di un' autorizzazione DEKRA all'uso del marchio DEKRA VERIFIED INVERTER, il presente attestato di conformità autorizza il costruttore a fare riferimento ai "Requisiti " in questo attestato, all'interno del marchio DEKRA VERIFIED INVERTER.

Product data:

MICRO-0.3-I-OUTD-230:

Operating Voltage Range: 12 Vdc to 60 Vdc

Operating Voltage Range @ max power: 30 Vdc to 50 Vdc

Maximum absolute Input Voltage: 65 Vdc

Maximum continuous input current 10,5 A (rms)

Output voltage: 230 Vac (single Phase)

Output voltage range: 180-264 Vac

Output frequency: 50 /60 Hz

Output current: 1,5 A

Maximum continuous output power: 300 W @ +65 °C ambient

Operating ambient temperature -40 °C to +75 °C

MICRO-0.25-I-OUTD-230 and MICRO-0.25-I-OUTD-230-ACPV

Operating Voltage Range: 12 Vdc to 60 Vdc

Operating Voltage Range @ max power: 30 Vdc to 50 Vdc

Maximum absolute Input Voltage: 65 Vdc

Maximum continuous input current 10,5 A (rms)

Output voltage: 230 Vac (single Phase)

Output voltage range: 180-264 Vac

Output frequency: 50 / 60 Hz


Output current: 1,3 A

Maximum continuous output power: 250 W @ +65 °C ambient

Operating ambient temperature -40 °C to +75 °C

Date of issue

Emesso in data : 2014/02/21



Franco Vasta
Certification manager

DEKRA Testing and Certification S.r.l.

Via Martiri della Liberazione, 12
23875 Osnago (LC)

Telephone: +39. 039.9280293

Fax: +39. 039.9280294

e-mail franco.vasta@dekra.com

Date 03/06/2014

To:

Power-One Italy S.p.A.
Via S. Giorgio, 642

52028 Terranuova Bracciolini (AR)
Italy

Subject: Transition over the ABB mark

With reference to your letter dated April 29, 2014 concerning the full integration of "Power-One" into "ABB" and the transition over to the ABB name, brand and brand standards starting from 1st May 2014, herewith DEKRA confirms that all Certificates/Attestation of Conformity and Test Report issued by DEKRA to the License Holder Power-One Italy S.p.A. referring to products with Trade Mark "Power-One Italy" can be considered still valid even if the products are branded with the new Trade Mark "ABB".

The License Holder of the products remains Power-One Italy S.p.A., legal names of the factory locations and model numbers, technical identity and type designation of the products presently manufactured with Power-One Trade Mark are not being changed with the exception of the new Trade Mark ABB.

It is full responsibility of the manufacturer to ensure that the series production is identical to the tested samples over the time and therefore presumed to be still in compliance with the stated standard.

Best regards,

Franco Vasta
Executive
Service Unit Product Testing and Certification
DEKRA Testing and Certification S.r.l.



DEKRA Testing and Certification S.r.l.
Cinisello Balsamo
(Sede legale)
Via Fratelli Gracchi 27 – Torre Nord
20092 Cinisello Balsamo (MI)
Capitale Sociale Euro 101.490
C.F. e P.IVA: 02894270962

Tel.: +39.02.6901-5526
Fax: +39.02.6001-5766

Roma
Via Olindo Guerrini, 10
00137 Roma (RM)
Tel.: +39.06.87203-01
Fax: +39.06.87203-029

Osnago
Via Martiri della Liberazione, 12
23875 Osnago (LC)
Tel.: +39.039.928.0293
Fax: +39.039.928.0294

Torino
Via Polesine, 1/4
10020 Cambiano (TO)
Tel.: +39.011.198208-10
Fax: +39.011.198208-14

Imola
(Autodromo Internazionale Enzo
e Dino Ferrari)
Via Fratelli Rosselli, 2
40026 Imola (BO)
Tel.: +39.0542.06623-0
Fax: +39.0542.06623-4