

TÜV Rheinland Italia S.r.l.
Sicurezza e Qualità Prodotto

To:
Gianfranco Iannuzzi
Power-One Italy S.p.A
Via S. Giorgio, 642 - 52028
Terranuova Bracciolini, Arezzo,
Italy

Antonio Somma
Tel: +39.02.939.687.54
Fax: +39.02.939.687.23
E-mail : antonio.somma@it.tuv.com

Pogliano Milanese, 28.01.2019

Object : Summary of tests included in report 28112188 014.

Dear Customer,

With the reference to the test report no. **28112188 014** issued by **TÜV Rheinland Italia S.r.l.** for your product **PVS-175-TL (& derived)** according to the standards **DIN V VDE V 0126-1-1:2013-08; DIN V VDE V 0126-1-1:2006 + A1: 2012** we summarize here the following details included in the test report:

- Your product is out of the scope of the standard, since it is not designed to be connected to LV grid.
- Your product partially meets the following requirement:
 - o 4.2 Voltage monitoring;
 - o Protection line to neutral have not been tested since the unit does not provide neutral connection.
- Your product have not been tested according to the following requirements:
 - o 4.5 Detection of island operation;
 - o The unit does not provide neutral connection, therefore testing is not possible. However the unit comply to IEC 62116:2014 (See Test report 28112188 006)

We remain at your complete disposal for any other request or support.

Best regards.

TÜV Rheinland Italia S.r.l.



Antonio Somma