



ENA Engineering Recommendation G83/2-1 Appendix 4 Type Verification Test Report

Type Approval and manufacturer/supplier declaration of compliance with the requirements of Engineering Recommendation G83/2-1			
SSEG (Small-Scale Embedded Generator) Type reference number		REACT2-UNO-3.6-TL	
SSEG Type		SOLAR GRID TIED INVERTER	
System Supplier name		Power-One Italy S.p.A.	
Address		Via S. Giorgio, 642 52028 Terranuova Bracciolini Arezzo – Italy	
Tel.	+39-055-91951	Fax	+39-055-9195248
E:mail	servicer.solarinverters@it.abb.com	Web site	www.abb.com/solarinverters www.abb.com
Nominal / Maximum rated capacity	Connection Option		
	3.6 kW / 3.6 kW	kW single phase	
<p>We, Power-One Italy S.p.A., as manufacturer/supplier of Small Scale Embedded Generators, certifies that all products manufactured/supplied by the company with the above SSEG Type reference number will be manufactured and tested to ensure that they perform as stated in this Type Verification Test Report, prior to shipment to site and that no site modifications are required to ensure that the products meet all the requirements of G83/2.</p> <p>Attachment: Extract of Test Report Ref. 28111587 026, Determination of Electrical Properties, released by TUEV Rheinland.</p>			

Terranuova B.ni, 2018 October 24


 Alessandro Rossi
 (Project Manager)


 Paolo Casini
 (GPG R&D Manager)

Extract of Test report: 28111587 026
“Determination of electrical properties”

Seite 1 von 9
Page 1 of 9

Appendix 4 Type Verification Test Report (G83/2)

Type of System:	Solar Grid tied inverter										
System Manufacturer: Manufacturer data:	Power-One Italy S.p.A. Via S. Giorgio 642, 52028 Terranuova Bracciolini (AR) - Italy										
Reference test report:	28111587 026 Issued by TÜV Rheinland Italia S.r.l. on 03/10/2018										
Measuring period:	From 17/09/2018 to 28/09/2018										
P_{acr}: (Rated AC Power) P_{acmax}: (Maximum AC output Power)		<table border="1"> <thead> <tr> <th></th> <th>REACT2-UNO-3.6-TL</th> <th>REACT2-UNO-5.0-TL</th> </tr> </thead> <tbody> <tr> <td>P_{acr} [W] @cosφ=1</td> <td>3600</td> <td>5000</td> </tr> <tr> <td>P_{acmax} [W] @cosφ=1</td> <td>3600</td> <td>5000</td> </tr> </tbody> </table>		REACT2-UNO-3.6-TL	REACT2-UNO-5.0-TL	P_{acr} [W] @cosφ=1	3600	5000	P_{acmax} [W] @cosφ=1	3600	5000
	REACT2-UNO-3.6-TL	REACT2-UNO-5.0-TL									
P_{acr} [W] @cosφ=1	3600	5000									
P_{acmax} [W] @cosφ=1	3600	5000									
Software version	Bundle Firmware Update Version ⁽²⁾ : not less than 1840C ⁽³⁾ with standard selection: UK G83										
Rated Voltage:	Single-phase device 230 V (Phase/ Neutral)										

Remarks:

(1) Model designation of the product:

Energy Storage System “Inverter+Battery Unit”:

Model Designation:	Description
REACT2-5.0-TL-OUTD	System composed by up to 3 REACT2-BATT and REACT2-UNO-5.0-TL hybrid PV inverter
REACT2-3.6-TL-OUTD	System composed by up to 3 REACT2-BATT and REACT2-UNO-3.6-TL hybrid PV inverter

“Hybrid” PV Inverter:

Model Designation	Description
REACT2-UNO-5.0-TL	5.0 KW 230V hybrid PV inverter. Hybrid means there is a PV DC input and a DC battery input
REACT2-UNO-3.6-TL	3.6 KW 230V hybrid PV inverter. Hybrid means there is a PV DC input and a DC battery input

Appendix 4 Type Verification Test Report (G83/2)

Battery Unit:

Model Designation:	Description:
REACT2-BATT	4 kWh battery system. Up to 3 units per system

Models REACT2-UNO-5.0-TL and REACT2-UNO-3.6-TL are identical in construction and they have the same release firmware version. They only differ in current/power limits controlled by software parameter setting.

The possible configurations for the Energy Storage System REACT2-5.0-TL-OUTD and REACT2-3.6-TL-OUTD are the following:

- Nr. 1 REACT2-UNO-5.0-TL + Nr. 1 REACT2-BATT
- Nr. 1 REACT2-UNO-5.0-TL + Nr. 2 REACT2-BATT
- Nr. 1 REACT2-UNO-5.0-TL + Nr. 3 REACT2-BATT
- Nr. 1 REACT2-UNO-3.6-TL + Nr. 1 REACT2-BATT
- Nr. 1 REACT2-UNO-3.6-TL + Nr. 2 REACT2-BATT
- Nr. 1 REACT2-UNO-3.6-TL + Nr. 3 REACT2-BATT

Tested Item composed by the following items:

Item Number	Model Designation	Serial number
3P819900000A	REACT2-UNO-5.0-TL	000002 (prototype selected by the customer)
3P889900000A	REACT2-UNO-3.6-TL	000002 (prototype selected by the customer)
3P729900000A	REACT2-BATT	000001 (prototype selected by the customer)

(2) “Update version” identifies the Bundle Firmware Features by a sequential code: xxxxy where:

- xxxx is a number indicates Year (two digits) and Week (two digits)
- y is a letter from A to G indicates Day (from Sunday = A to Saturday=G)

(3) Not less than: MICRO (Supervisor): C.2.3.8; Booster (DC-DC): A.0.1.5; Inverter (DC-AC): B.0.1.3
 CHARGER (DC-DC): H1.0.2

Extract of Test report: 28111587 026
 “Determination of electrical properties”

Seite 3 von 9
 Page 3 of 9

Appendix 4 Type Verification Test Report (G83/2)

Power Quality. Harmonics. The requirement is specified in section 5.4.1, test procedure in Annex A or B 1.4.1

SSEG rating per phase (rpp)			5.0 kW			
Harmonic	At 45-55% of rated output		100% of rated output		Mono Phase	
	Measured Value (MV) in Amps	Normalised Value (NV) in Amps	Measured Value (MV) in Amps	Normalised Value (NV) in Amps	Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above
2	0.0140	0.00129	0.0190	0.0009	1.080	
3	0.1330	0.01224	0.1480	0.0068	2.300	
4	0.0020	0.00018	0.0030	0.0001	0.430	
5	0.0660	0.00607	0.0650	0.0030	1.140	
6	0.0030	0.00028	0.0020	0.0001	0.300	
7	0.0190	0.00175	0.0250	0.0011	0.770	
8	0.0020	0.00018	0.0010	0.0000	0.230	
9	0.0160	0.00147	0.0130	0.0006	0.400	
10	0.0010	0.00009	0.0010	0.0000	0.184	
11	0.0130	0.00120	0.0100	0.0005	0.330	
12	0.0020	0.00018	0.0010	0.0000	0.153	
13	0.0120	0.00110	0.0080	0.0004	0.210	
14	0.0010	0.00009	0.0010	0.0000	0.131	
15	0.0100	0.00092	0.0080	0.0004	0.150	
16	0.0010	0.00009	0.0010	0.0000	0.115	
17	0.0090	0.00083	0.0050	0.0002	0.132	
18	0.0010	0.00009	0.0010	0.0000	0.102	
19	0.0060	0.00055	0.0040	0.0002	0.118	
20	0.0010	0.00009	0.0010	0.0000	0.092	
21	0.0060	0.00055	0.0030	0.0001	0.107	
22	0.0000	0.00000	0.0010	0.0000	0.084	
23	0.0030	0.00028	0.0020	0.0001	0.098	0.147
24	0.0000	0.00000	0.0010	0.0000	0.077	
25	0.0030	0.00028	0.0010	0.0000	0.090	0.135
26	0.0000	0.00000	0.0010	0.0000	0.071	
27	0.0040	0.00037	0.0020	0.0001	0.083	0.124
28	0.0010	0.00009	0.0000	0.0000	0.066	
29	0.0020	0.00018	0.0010	0.0000	0.078	0.117
30	0.0010	0.00009	0.0000	0.0000	0.061	
31	0.0030	0.00028	0.0020	0.0001	0.073	0.109
32	0.0010	0.00009	0.0000	0.0000	0.058	
33	0.0020	0.00018	0.0010	0.0000	0.068	0.102
34	0.0000	0.00000	0.0010	0.0000	0.054	
35	0.0020	0.00018	0.0020	0.0001	0.064	0.096
36	0.0010	0.00009	0.0010	0.0000	0.051	
37	0.0010	0.00009	0.0010	0.0000	0.061	0.091
38	0.0000	0.00000	0.0000	0.0000	0.048	
39	0.0020	0.00018	0.0030	0.0001	0.058	0.087
40	0.0020	0.00018	0.0020	0.0001	0.046	

Extract of Test report: 28111587 026
“Determination of electrical properties”

Seite 4 von 9
 Page 4 of 9

Appendix 4 Type Verification Test Report (G83/2)

Power Quality. Voltage fluctuations and Flicker. The requirement is specified in section 5.4.2, test procedure in Annex A or B 1.4.3

Parameter	Measured Value	Limit	Verdict
P _{st}	0.070	1.00	P
P _{lt}	0.070	0.65	P
d _c [%]	0.024	3.30	P
d _{max} [%]	0.098	4.00	P
dt [s]	0.000	0.50	P
Standard used:	EN/IEC 61000-3-3 Flicker		
Short time (P _{st}):	10 min		
Observation time:	120 min (12 Flicker measurements)		
Flickermeter:	230V / 50Hz according IEC 61000-4-15 Ed.2		
Flicker Impedance:	Zref (IEC 60725)		

Power quality. DC injection. The requirement is specified in section 5.5, test procedure in Annex A or B 1.4.4 (of reference document G83/2)

Test power level	10%	55%	100%
Recorded value	0.008A	0.018A	0.025A
as % of rated AC current	0.036 %	0.082 %	0.11 %
Limit	0.25 %	0.25 %	0.25 %

Power quality. Power Factor The requirement is specified in section 5.6, test procedure in Annex A or B 1.4.2

Nominal Values:	See General Product Information			
Ambient temperature (°C)	25°C ± 5°C			
Humidity (RH %)	65%RH			
Instrumentation list.....	See table “Measurement equipment and instrumentation”			
	216.3V	230.1V	253.2V	Measured at three voltage levels and at full output. Voltage to be maintained within ±1.5% of the stated level during the test.
Measured value	0.999	0.999	0.999	
Limit	>0.95	>0.95	>0.95	

Extract of Test report: 28111587 026
“Determination of electrical properties”

Seite 5 von 9
 Page 5 of 9

Appendix 4 Type Verification Test Report (G83/2)

Protection. Voltage tests The requirement is specified in section 5.3.1, test procedure in Annex A or B 1.3.2

Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage/Time	Confirm no trip
U/V stage 1	200.1V	2.55s	200.13	2.558	204.1V/3.5s	No Trip
U/V stage 2	184V	0.55s	183.53	0.552	188V/2.48s	No Trip
					180V/0.48s	No Trip
O/V stage 1	262.2V	1.0s	262.16	1.044	258.2V/2.0s	No Trip
O/V stage 2	273.7V	0.5s	273.69	0.541	269.7V/0.98s	No Trip
					277.7V/ 0.48s	No Trip

Protection. Frequency tests The requirement is specified in section 5.3.1, test procedure in Annex A or B 1.3.3

Protection. Frequency tests.

Function	Setting		Trip test		“No trip tests”	
	Frequency	Time delay	Frequency	Time delay	Frequency /time	Confirm no trip
U/F stage 1	47.5Hz	20.05s	47.45	20.096	47.7Hz/ 25s	No Trip
U/F stage 2	47Hz	0.55s	46.95	0.565	47.2Hz/ 19.98s	No Trip
					46.8Hz/ 0.48s	No Trip
O/F stage 1	51.5Hz	90.05s	51.55	90.047	51.3Hz/95s	No Trip
O/F stage 2	52Hz	0.55s	52.05	0.542	51.8Hz/ 89.98s	No Trip
					52.2Hz/ 0.48s	No Trip

Extract of Test report: 28111587 026
“Determination of electrical properties”

Seite 6 von 9
Page 6 of 9

Appendix 4 Type Verification Test Report (G83/2)

Protection. Loss of Mains test. The requirement is specified in section 5.3.2, test procedure in Annex A or B 1.3.4

No	P _{EUT} ¹⁾ (% of EUT rating)	Reactive load (% of Q _L in 6.1.d)1)	P _{AC} ²⁾ (% of nominal)	Q _{AC} ³⁾ (% of nominal)	Run on time (ms)**	P _{EUT} (W)	V _{DC} (V)	Remarks ⁴⁾	Verdict
1	100	100	0	0	769.6	5000	439	Test A at BL	P
2	66	66	0	0	807.6	3300	328	Test B at BL	P
3	33	33	0	0	795.6	1188	216	Test C at BL	P
4	100	100	-5	-5	715.6	5000	439	Test A at IB	P
5	100	100	-5	0	687.6	5000	439	Test A at IB	P
6	100	100	-5	+5	623.6	5000	439	Test A at IB	P
7	100	100	0	-5	715.6	5000	439	Test A at IB	P
8	100	100	0	+5	613.6	5000	439	Test A at IB	P
9	100	100	+5	-5	699.6	5000	439	Test A at IB	P
10	100	100	+5	0	891.6	5000	439	Test A at IB	P
11	100	100	+5	+5	609.6	5000	439	Test A at IB	P
12	66	66	0	-5	639.6	3300	328	Test B at IB	P
13	66	66	0	-4	701.6	3300	328	Test B at IB	P
14	66	66	0	-3	731.6	3300	328	Test B at IB	P
15	66	66	0	-2	651.6	3300	328	Test B at IB	P
16	66	66	0	-1	737.6	3300	328	Test B at IB	P
17	66	66	0	1	673.6	3300	328	Test B at IB	P
18	66	66	0	2	647.6	3300	328	Test B at IB	P
19	66	66	0	3	641.6	3300	328	Test B at IB	P
20	66	66	0	4	623.6	3300	328	Test B at IB	P
21	66	66	0	5	619.6	3300	328	Test B at IB	P
22	33	33	0	-5	647.6	1188	216	Test C at IB	P
23	33	33	0	-4	675.6	1188	216	Test C at IB	P
24	33	33	0	-3	677.6	1188	216	Test C at IB	P
25	33	33	0	-2	695.6	1188	216	Test C at IB	P
26	33	33	0	-1	697.6	1188	216	Test C at IB	P
27	33	33	0	1	727.6	1188	216	Test C at IB	P
28	33	33	0	2	673.6	1188	216	Test C at IB	P
29	33	33	0	3	667.6	1188	216	Test C at IB	P
30	33	33	0	4	641.6	1188	216	Test C at IB	P
31	33	33	0	5	651.6	1188	216	Test C at IB	P
32	100	100	-10	-10	617.6	5000	439	Test A at IB	P
33	100	100	-10	-5	709.6	5000	439	Test A at IB	P
34	100	100	-10	0	709.6	5000	439	Test A at IB	P
35	100	100	-10	+5	615.6	5000	439	Test A at IB	P
36	100	100	-10	+10	603.6	5000	439	Test A at IB	P
37	100	100	-5	+10	603.6	5000	439	Test A at IB	P

Extract of Test report: 28111587 026
“Determination of electrical properties”

 Seite 7 von 9
 Page 7 of 9

Appendix 4 Type Verification Test Report (G83/2)

Protection. Loss of Mains test. The requirement is specified in section 5.3.2, test procedure in Annex A or B 1.3.4

No	$P_{EUT}^{1)}$ (% of EUT rating)	Reactive load (% of Q_L in 6.1.d)1)	$P_{AC}^{2)}$ (% of nominal)	$Q_{AC}^{3)}$ (% of nominal)	Run on time (ms)**	P_{EUT} (W)	V_{DC} (V)	Remarks ⁴⁾	Verdict
38	100	100	0	+10	597.6	5000	439	Test A at IB	P
39	100	100	+5	+10	583.6	5000	439	Test A at IB	P
40	100	100	-5	-10	617.6	5000	439	Test A at IB	P
41	100	100	0	-10	593.6	5000	439	Test A at IB	P
42	100	100	+5	-10	597.6	5000	439	Test A at IB	P
43	100	100	+10	-10	601.6	5000	439	Test A at IB	P
44	100	100	+10	-5	691.6	5000	439	Test A at IB	P
45	100	100	+10	0	843.6	5000	439	Test A at IB	P
46	100	100	+10	+5	625.6	5000	439	Test A at IB	P
47	100	100	+10	+10	589.6	5000	439	Test A at IB	P

¹⁾ P_{EUT} : EUT output power

²⁾ P_{AC} : Real power flow at S1 as in Figure 1. Positive value means the power from EUT to utility. Nominal value is the 0% test condition value.

³⁾ Q_{AC} : Reactive power flow at S1 as in Figure 1. Positive value means the power from EUT to utility. Nominal value is the 0% test condition value

⁴⁾ BL: Balance condition, IB: Imbalance condition

*: Needs to be measured if any of the recorded run-on times at imbalanced condition are longer than the one recorded for the rated balance condition at test condition A

** “Run on time” must be < 2s

The filled out switch-off time values the highest among the three phase

Extract of Test report: 28111587 026
“Determination of electrical properties”

Seite 8 von 9
 Page 8 of 9

Appendix 4 Type Verification Test Report (G83/2)

Protection. Re-connection timer. The requirement is specified in section 5.3.4, test procedure in Annex A or B 1.3.5 (of reference document G83/2)

Time delay setting	Measured delay	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.			
20s	24s	At 254.7V	At 196.2V	At 47.6Hz	At 51.4Hz
Confirmation that the SSEG does not re-connect.		No reconnection	No reconnection	No reconnection	No reconnection

Protection. Frequency change, Stability test The requirement is specified in section 5.3.3, test procedure in Annex A or B 1.3.6 (of reference document G83/2)

	Start Frequency	Change	End Frequency	Confirm no trip
Positive Vector Shift	49.5Hz	+9 degrees		No trip
Negative Vector Shift	50.5Hz	- 9 degrees		No trip
Positive Frequency drift	49.5Hz	+0.19Hz/sec	51.5Hz	No trip
Negative Frequency drift	50.5Hz	-0.19Hz/sec	47.5Hz	No trip

Fault level contribution. The requirement is specified in section 5.7, test procedure in Annex A or B 1.4.6 (of reference document G83/2)

Time after fault	Volts	Amps (rms)
20ms	20.02	21.72
60ms	10.65	10.81
100ms	7.59	6.78
1000ms	4.56	4.12
Time to trip	<1	In seconds

Extract of Test report: 28111587 026
“Determination of electrical properties”

Seite 9 von 9
Page 9 of 9

Appendix 4 Type Verification Test Report (G83/2)

This extract from the test report is only valid in conjunction with the test report no.: **28111587 026**

Reviewed by:

03.10.2018	Marco Piva / BFM	
Datum	Name/Stellung	Unterschrift
<i>Date</i>	<i>Name/Position</i>	<i>Signature</i>