

Attention to:

Power-One Italy S.p.A.

Via San Giorgio 642, 52028
Terranuova Bracciolini – AR – Italy

Pogliano Milanese. 26.04.2019

Subject : Declaration _ COMMISSION REGULATION (EU) 2016/631 (RfG)

We confirm you that evaluation activities according **EN 50549-2** on your product:

Solar Grid Tied Inverter

Model(s):

- **UNO-DM-X.X-TL-PLUS-XYK-JVN-DIP**
Where X.X may be 1.2 or 2.0 or 3.0 or 3.3 or 4.0 or 4.6 or 5.0 or 6.0
XYK may be X: "blank" or S Y: "blank" or B or E; K: "blank"
JVN may be J: "blank" or X; V: "blank" or G; N: "blank"
DIP may be D: "blank" or Q; I: "blank" or U; P: "blank"
- **REACT2-UNO-5.0-TL, REACT2-UNO-3.6-TL**
Remark: may be used in combination with a maximum of Three Battery Units,
model REACT2-BATT
- **TRIO-TM-50.0-400; TRIO-TM-60.0-480**
- **PVS-50-TL, PVS-50-TL-S, PVS-50-TL-SX, PVS-50-TL-SX2**
- **PVS-60-TL, PVS-60-TL-S, PVS-60-TL-SX, PVS-60-TL-SX2, PVS-60-TL-SX-CN**
- **PVS-100-TL, PVS-120-TL**
- **PVI-X-TL-OUTD-Y** (Note 1)
Where X may be 12.5 or 10.0 or 8.0 or 6.0 and Y may be "blank" or S or FS
- **TRIO-X-TL-OUTD-Y-400** (Note 1)
Where X may be 8.5 or 7.5 or 5.8 and Y may be "blank" or S
- **TRIO-X-TL-OUTD-Y-400** (Note 1)
Where X may be 27.6 or 20.0 and Y may be "blank" or S2 or S2X or S2F or S1J or S2J


were completed with successful results.

We confirm that products above listed meets the requirements of:

- **Requirements for Type A and Type B Generation Units**
- **COMMISSION REGULATION (EU) 2016/631 (RfG)**
- **EN 50549-2:2019**

We remain at your complete disposal for any clarifications.

Best regards



Marco Piva

Regional Field Manager Solar

TÜV Rheinland Italia S.r.l.
Sede Legale ed operativa
Membro del Gruppo
TÜV Rheinland

Via Mattei, 3
20010 Pogliano Milanese (MI)

Tel: +39.02.939.687.1
Fax: +39.02.939.687.23
E-mail: informazioni@it.tuv.com
Web: www.tuvitalia.com

Capitale sociale
EURO 51.000,00 int. versato
C.C.I.A.A. Milano No. 1535451
Registro Milano No. 214918
CF e IVA 12184570153