

Certificate



Certificate no.

CU 72150214 01

License Holder:

Power-One
3201 East Harbour Drive
Phoenix AZ 85034
USA

Manufacturing Plant:

ABB Inc.
16250 W Glendale Drive
New Berlin WI 53151
USA

Test report no.: USA-ZZ 31580190 001

Client Reference: Bob White

Tested to: UL 1741:2010
CSA C22.2.107.1-01 (R2006)

Certified Product: Rapid Shut Down Device

License Fee - Units

Model Designation: 1) RS4-2CN6, 2) RS2-2PN6, 3) RS2-1CN6
(trademark: ABB) 7

Rated Voltage: DC 90-580V

Rated Current: 10A max. (per channel)

Protection Class: I

Max. Short-Circuit Current (input/output): 1), 3) 11.25/22.5A
2) 22.5A

contd.


Special Remarks: To be installed according to the licensee's
installation instructions.

Also evaluated to NFPA 70: 2014, Article 690.12.

7

Appendix: 1, 1-6

Licensed Test mark:



Date of Issue

(day/mo/yr)

13/04/2015

Certificate



Certificate no.

CU 72150214 02

License Holder:

Power-One
3201 East Harbour Drive
Phoenix AZ 85034
USA

Manufacturing Plant:

ABB Inc.
16250 W Glendale Drive
New Berlin WI 53151
USA

Test report no.: USA-ZZ 31580190 001

Client Reference: Bob White

Tested to: UL 1741:2010
CSA C22.2.107.1-01 (R2006)

Certified Product: Rapid Shut Down Device

License Fee - Units


contd.

Output Current: 1) 20A max. (per channel)
2) 10A max. (per channel)
3) 20A max.

Rated Ambient Temperature: -25°C to +70°C

Enclosure Index: Type 4X

Licensed Test mark:



Date of Issue

(day/mo/yr)

13/04/2015