

Attention to:

POWER-ONE ITALY S.P.A.

Via San Giorgio 642, 52028 Terranuova Bracciolini – AR – Italy

Pogliano Milanese. 17/02/2014

Subject: EN 62109-1 Statement of Conformity
Reference no. STATEMENT_28104860_001

With reference to the following Photovoltaic Grid tied inverters, model:

ULTRA-700-0-TL ULTRA-1050-0-TL ULTRA-1400-0-TL

We confirm that from the analysis of the results provided on the following Test Reports, showing compliance to the requirements of **EN 60529:1991 + A1:2000**:

test report no. 287646 issued by Istituto Giordano on 25th October 2011 test report no. 294054 issued by Istituto Giordano on 27th April 2012 test report no. 298752 issued by Istituto Giordano on 11th October 2012

The IP Protection Degree can be still considered **IP 65** even when Inverter is assembled by the following supplier:

- Cometi S.p.A.
- Metaltecnica S.r.l.
- Cioncolini S.r.l.

The above listed test reports should be included in Appendix 7 of test report no. 28104860 001 issued by TÜV Rheinland Italia S.r.l. on 23th July 2012 according to **EN 62109-1:2010** moreover, the statement on page 20 item 6.3 should be modified from present "See Appendix 9" to the new statement "See Appendix 7".

We remain at your complete disposal for any clarifications. Best regards

Mario Comboni

Product Manager Solar/Fuel Technology Business Stream Products TÜV Rheinland Italia S.r.I. Sede Legale ed operativa Membro del Gruppo TÜV Rheinland

Via Mattei, 3 20010 Pogliano Milanese (MI)

Tel: +39.02.939.687.1 Fax: +39.02.939.687.23 E-mail:informazioni@it.tuv.com Web:www.tuvitalia.com

Capitale sociale EURO 51.000,00 int. versato C.C.I.A.A. Milano No. 1535451 Registro Milano No. 214918 CF e IVA 12184570153