

Certificate UK-G83 issue 2

The results of the G83/2 tests are summarized in this certificate.

Power-One Italy S.p.a. declares that the units installed in UK market and set for G83/2 operations are characterized by the following features:

- The internal specification and parameters are set to be compliant with: Engineering Recommendation G83 issue 2, 2012.
- All units have internal parameters setting.
- These parameters cannot be changed by user, an installer or by any person other than the manufacturer (Password protected).
- All units are tested before shipping according to: Engineering Recommendation G83 issue 2, 2012.

SSEG Type reference number			PHOTO-VOLTAIC Microinverter					
SSEG Type		MICRO-0.3-I-OUTD-230 MICRO-0.25-I-OUTD-230						
System Supplier	name	Power-	One Italy S	p.a				
Address			Giorgio, 642 Terranuova					
Tel	+39-055-91951	Arezzo Fax	- Italy	+39-055-9195248				
E:mail	service@power-one.com		Web site	www.power-one.com				
			Connec	tion Option				
	0.3	kW sin	gle phase (I	MICRO-I-0.3-OUTD-230)				
	0.25	kW sin	gle phase (I	MICRO-I-0.25-OUTD-230)				
Maximum rated								
capacity	NA	kW three phase						
	NA	kW two	o phases in	three phase system				
	NA	kW two	o phases sp	lit phase system				

SSEG manufacturer/supplier declaration

I certify on behalf of the company named above as a manufacturer/supplier of Small Scale Embedded Generators, that all products manufactured/supplied by the company with the above SSEG Type reference number will be manufactured and tested to ensure that they perform as stated in this Type Verification Test Report, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of G83/2.

Signed	withofit for	On behalf of	Power-One, Renewable Energy Solutions
--------	--------------	-----------------	---------------------------------------

Report Date: 2013-04-03 www.power-one.com Page 1 of 8 File: Micro_0 3-0 25_G83 issue 2 Certificate_Updated 09-04-2013



UK-G83 issue 2 TEST RESULT DETAILS - TYPE VERIFICATION TEST SHEET

MICRO-0.3-I-OUTD-230

Power	Qua	lity.	Har	mon	ics.
-------	-----	-------	-----	-----	------

Power Quality. Harmonics.										
SSEG	a rating per pha	se (rpp)	2.104 (7 units) kW	NV=MV*	*3.68/rpp				
Harmonic	At 45-55% c	of rated output	100% of ra	ited output						
	Measured	Normalised	Measured	Normalised	Limit in BS EN	Higher limit for				
	Value (MV)	Value (NV) in	Value (MV) in	Value (NV) in	61000-3-2 in	odd harmonics				
	in Amps	Amps	Amps	Amps	Amps	21 and above				
2	0.028	0.049	0.061	0.107	1.080					
3	0.042	0.074	0.163	0.284	2.300					
4	0.010	0.018	0.012	0.021	0.430					
5	0.029	0.051	0.038	0.067	1.140					
6	0.008	0.014	0.006	0.010	0.300					
7	0.036	0.062	0.031	0.055	0.770					
8	0.008	0.013	0.010	0.017	0.230					
9	0.020	0.035	0.029	0.051	0.400					
10	0.006	0.011	0.004	0.007	0.184					
11	0.005	0.009	0.027	0.046	0.450					
12	0.005	0.009	0.004	0.007	0.153					
13	0.014	0.024	0.026	0.045	0.210					
14	0.005	0.008	0.005	0.009	0.131					
15	0.021	0.037	0.024	0.041	0.150					
16	0.002	0.004	0.004	0.006	0.115					
17	0.025	0.043	0.021	0.036	0.132					
18	0.002	0.004	0.006	0.010	0.102					
19	0.023	0.040	0.016	0.027	0.118					
20	0.004	0.007	0.005	0.008	0.092					
21	0.021	0.036	0.016	0.027	0.107					
22	0.003	0.005	0.004	0.007	0.084					
23	0.021	0.036	0.016	0.028	0.098	0.147				
24	0.003	0.005	0.003	0.005	0.077					
25	0.018	0.032	0.022	0.038	0.090	0.135				
26	0.002	0.004	0.003	0.005	0.071					
27	0.017	0.029	0.024	0.041	0.083	0.124				
28	0.002	0.004	0.003	0.006	0.066					
29	0.010	0.017	0.027	0.047	0.078	0.117				
30	0.002	0.004	0.002	0.004	0.061					
31	0.005	0.009	0.025	0.043	0.073	0.109				
32	0.003	0.005	0.003	0.005	0.058					
33	0.004	0.007	0.024	0.041	0.068	0.102				
34	0.002	0.003	0.003	0.005	0.054					
35	0.008	0.014	0.019	0.033	0.064	0.096				
36	0.002	0.003	0.003	0.006	0.051					
37	0.010	0.017	0.013	0.022	0.061	0.091				
38	0.003	0.004	0.003	0.006	0.048					
39	0.010	0.017	0.005	0.009	0.058	0.087				
40	0.002	0.004	0.003	0.006	0.046					

Report Date: 2013-04-08 Page 2 of 8 www.power-one.com

File: Micro_0 3-0 25_G83 issue 2 Certificate_Updated 09-04-2013

This document and the contents herein are the confidential property of Power-One Italy S.p.a.

It shall not be reproduced, changed, or altered in any way and is for the internal use of Power-One only.

Power-One Italy Via S. Giorgio, 642 52028 Terranuova Bracciolini Arezzo – Italy Phone +39 055 9195 1 Fax +39 055 9195 248



MICRO-0.25-I-OUTD-230

DOWAR	Oua	litv	Harr	monics.
ruwei	uua	IILV.	пан	HUHILS.

Power Quality. Harmonics.										
SSEC	a rating per pha	ase (rpp)	2.042(0.25)	kW						
Harmonic	armonic At 45-55% of rated output			ated output	NV=MV*3.68/rpp					
	Measured Value (MV) in Amps	Normalised Value (NV) in Amps	Measured Value (MV) in Amps	Normalised Value (NV) in Amps	Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above				
2	0.024	0.043	0.077	0.139	1.080					
3	0.041	0.074	0.130	0.233	2.300					
4	0.009	0.015	0.020	0.036	0.430					
5	0.063	0.114	0.043	0.077	1.140					
6	0.003	0.005	0.010	0.018	0.300					
7	0.036	0.065	0.032	0.057	0.770					
8	0.004	0.007	0.011	0.019	0.230					
9	0.038	0.068	0.028	0.050	0.400					
10	0.003	0.006	0.007	0.013	0.184					
11	0.033	0.060	0.025	0.046	0.450					
12	0.005	0.009	0.007	0.013	0.153					
13	0.019	0.033	0.025	0.045	0.210					
14	0.005	0.009	0.004	0.006	0.131					
15	0.012	0.021	0.022	0.040	0.150					
16	0.002	0.004	0.006	0.010	0.115					
17	0.022	0.040	0.021	0.037	0.132					
18	0.002	0.004	0.005	0.009	0.102					
19	0.024	0.043	0.018	0.032	0.118					
20	0.003	0.005	0.007	0.012	0.092					
21	0.013	0.024	0.015	0.026	0.107					
22	0.002	0.004	0.005	0.008	0.084					
23	0.008	0.015	0.014	0.025	0.098	0.147				
24	0.002	0.003	0.004	0.007	0.077					
25	0.020	0.036	0.029	0.052	0.090	0.135				
26	0.003	0.006	0.003	0.005	0.071					
27	0.018	0.032	0.028	0.051	0.083	0.124				
28	0.004	0.006	0.005	0.009	0.066					
29	0.012	0.022	0.027	0.048	0.078	0.117				
30	0.002	0.003	0.004	0.008	0.061					
31	0.011	0.019	0.026		0.073	0.109				
32	0.002	0.004	0.004	0.007	0.058					
33	0.008	0.015	0.024	0.043	0.068	0.102				
34	0.002	0.004	0.003	0.005	0.054	0.000				
35	0.003	0.006	0.018	0.033	0.064	0.096				
36	0.002	0.003	0.004	0.008	0.051	2.25				
37	0.011	0.020	0.016	0.028	0.061	0.091				
38	0.003	0.005	0.004	0.007	0.048	2 25=				
39	0.015	0.026	0.005	0.009	0.058	0.087				
40	0.003	0.006	0.003	0.006	0.046					

Report Date: 2013-04-08 Page 3 of 8 www.power-one.com

File: Micro_0 3-0 25_G83 issue 2 Certificate_Updated 09-04-2013

This document and the contents herein are the confidential property of Power-One Italy S.p.a.

It shall not be reproduced, changed, or altered in any way and is for the internal use of Power-One only.

Power-One Italy Via S. Giorgio, 642 52028 Terranuova Bracciolini Arezzo – Italy Phone +39 055 9195 1 Fax +39 055 9195 248



MICRO-0.3-I-OUTD-230										
Power Quality. Voltage fluctuations and Flicker.										
		Starting			Stopp	oing			Running	
	dmax [%]	dc [%]	d(t) [%]	dmax [%]	dc [%	6]	d(t) [%]	Pst	Plt 2 hours	
Measured Values	0.39	0.28	0.32	1.81	0.28		0.32	0.235	0.188	
Normalised to standard impedance and 3.68kW for multiple units	0.68	0.49	0.56	3.17	0.49		0.56	0.41	0.329	
Limits set under BS EN 61000-3-3	4%	3.30%	3.3% 500ms	4%	4% 3.30%		3.3% 500ms	1	0.65	
Test start date	10\10\2012			Test end d	Test end date 10\10\2012					
Test location	Power One	taly S.p.	a. Via S.Gic	orgio, 642	52028	Teri	ranuova Bra	acciolini .	Arezzo - Italy	

MICRO-0.25-I-OUTD-230										
Power Quality. Voltag	ge fluctuation	ns and Fl	icker.							
		Starting			Stopp	oing		Running		
	dmax [%]	dc [%]	d(t) [%]	dmax [%]	dc [%	d(t) [%	j] Pst	Plt 2 hours		
Measured Values	1.22	0.47	1.08	1.94	1.68	0.47	0.47	0.309		
Normalised to standard impedance and 3.68kW for multiple units	2.19	0.84	1.93	3.48	3.01	0.84	0.847	0.556		
Limits set under BS EN 61000-3-2	4%	3.30%	3.3% 500ms	4%	3.30%	3.3% 500ms	1	0.65		
Test start date	25\09\2012			Test end date 25\09\2012			2			
								·		
Test location	Power One	Italy S.p.	a. Via S.Gio	orgio, 642	52028	Terranuova	Bracciolini	Arezzo - Italy		



	MICRO-0.3-I-OUTD-230							
Power quality. DC injection								
Test power level	10%	55%	100%					
Recorded value(A)	0.01963	0.00955	0.00276					
as % of rated AC current	0.21%	0.10%	0.03%					
Limit	0.25%	0.25%	0.25%					

	MICRO-0.25-I-OUTD-230							
Power quality. DC injection								
Test power level	10%	55%	100%					
Recorded value(A)	0.01547	0.00756	0.00771					
as % of rated AC current	0.17%	0.09%	0.09%					
Limit	0.25%	0.25%	0.25%					

MICRO-0.3-I-OUTD-230									
Power Quality. Power factor.									
	216.2V	230V	253V						
Measured value	0.9979	0.9974	0.9969	Measured at three voltage levels and at full output. Voltage to be maintained within ±1.5% of the stated level during the test.					
Limit	>0.95	>0.95	>0.95	level during the test.					

MICRO-0.25-I-OUTD-230									
Power Quality. Power factor.									
	216.2V	230V	253V						
Measured value	0.9979	0.9977	0.9969	Measured at three voltage levels and at full output. Voltage to be maintained within ±1.5% of the stated level during the test.					
Limit	>0.95	>0.95	>0.95	level during the test.					

Report Date: 2013-04-08 www.pow	ver-one.com Page 5 of 8
---------------------------------	-------------------------



MICRO-0.3-I-OUTD-230 and MICRO-0.25-I-OUTD-230								
Protection. Fr	equency tests.							
Function	Set	ting	Trip	test	"No trip	tests"		
	Frequency	Time delay	Frequency	Time delay	Frequency /time	Confirm no trip		
U/F stage 1	47.5Hz	20s	47.49Hz	22s	47.7Hz/ 25s	No trip		
U/F stage 2	47Hz	0.5s	46.98Hz	0.542s	47.2Hz/ 19.98s	No trip		
					46.8Hz/ 0.48s	No trip		
O/F stage 1	51.5Hz	90s	51.51Hz	92s	51.3Hz/95s	No trip		
O/F stage 2	O/F stage 2 52Hz 0.5s 52.01Hz 0.558s 51.8Hz/89.98s No trip							
	52.2Hz/ 0.48s No trip							

MICRO-0.3-I-OUTD-230 and MICRO-0.25-I-OUTD-230								
Protection. V	oltage tests.							
Function Setting Trip test "No trip tests"								
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip		
U/V stage 1	200.1V	2.5s	199.5V	2.57s	204.1V/3.5s	No trip		
U/V stage 2	184V	0.5s	183.1V	0.558s	188V/2.48s	No trip		
					180V/0.48s	No trip		
O/V stage 1	262.2V	1.0s	261.6V	1.07s	258.2V/2.0s	No trip		
O/V stage 2	273.7V	0.5s	273.1V	0.558s	269.7V/0.98s	No trip		
					277.7V/0.48s	No trip		



MICRO-0.3-I-OUTD-230							
Protection. Loss of Mains test.							
Note: Inverter tested acco	Note: Inverter tested according to BS EN 62116.						
Test Power and imbalance 33% 66% 100% 33% 66% 100% 100% 100% 100% 100% 100% 100%							
Trip time. Limit is 0.5s	495ms	265ms	245ms	301ms	341ms	165ms	

MICRO-0.25-I-OUTD-230							
Protection. Loss of Mains test.							
Note: Inverter tested acco	Note: Inverter tested according to BS EN 62116.						
Test Power and imbalance 33% 66% 100% 33% 66% 100% 100% 100% 100% 100% 100% 100%							
Trip time. Limit is 0.5s	323ms	331ms	315ms	303ms	267ms	293ms	

MICRO-0.3-I-OUTD-230 and MICRO-0.25-I-OUTD-230								
Protection. Frequency change, Stability test								
	Start Frequency Change End Frequency Confirm no trip							
Positive Vector Shift	49.5Hz	+9 degrees		No trip				
Negative Vector Shift	Negative Vector Shift 50.5Hz - 9 degrees No trip							
Positive Frequency drift 49.5Hz +0.19Hz/sec 51.5Hz No trip								
Negative Frequency drift								

Fault level contribution.							
МІ	CRO-0.3-I-OUTD-2	30	MICRO-0.25-I-OUTD-230				
For a Inverter SSEG			For a Inverter SSEG				
Time after fault	Volts	Amps	Time after fault Volts Amps				
20ms	-31.797	0.58	20ms	33.98	0.52		
100ms	-31.836	0.36	100ms	34.06	0.32		
250ms	33.828	0.23	250ms	-31.68	0.24		
500ms	-31.367	0.17	500ms	33.68	0.24		
Time to trip	0.0874	(in seconds)	Time to trip	0.238	(in seconds)		

Report Date: 2013-04-08	www.power-one.com	Page 7 of 8
-------------------------	-------------------	-------------



MICRO-0.3-I-OUTD-230 and MICRO-0.25-I-OUTD-230

Protection. Re-connection timer.

Test proves that the reconnection sequence starts after a minimum delay of 20 seconds for restoration of voltage and frequency to within the stage 1 settings of table 1 of the subject normative.

Time delay setting	Measured delay	No reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.				
20s	43.2s	At 266.2V	At 196.1V	At 47.4Hz	At 51.6Hz	
Confirmation that the SSEG does not re-connect.		No reconnection	No reconnection	No reconnection	No reconnection	

MICRO-0.3-I-OUTD-230 and MICRO-0.25-I-OUTD-230

Self-Monitoring solid state switching.

It has been verified that in the event of the solid state switching device failing to disconnect the SSEG, the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 seconds.

End of Document —